

**From:** Jane Cooper <Jane.Cooper@midsussex.gov.uk>  
**Sent:** 11 June 2025 14:34:02 UTC+01:00  
**To:** "Steve Ashdown" <Steve.Ashdown@midsussex.gov.uk>  
**Subject:** DM/23/2866

Hi Steve,

The lighting report submitted 30/05/2025 produced by MEC Consulting Group Report Ref: 29283-LIGH-0401, dated December 2024 demonstrates that the proposed external lighting to the hockey pitches, padel courts and tennis courts at this development will comply with requirements for an E2 zone as outlined in Guidance Note 01/21 produced by the Institute of Lighting Professionals. Light from these sports pitches is therefore unlikely to affect the amenity of local residents.

I recommend that a condition be applied to any permission granted requiring that lighting to these sports pitches be installed in compliance with the above report. I can't comment on external lighting to the car park serving these facilities, or to other community buildings/public outside spaces as these are not mentioned in the report.

Please note that I can't comment on how the light will affect wildlife in the area.

I don't think any of the other documents submitted on 30/05/25 require my comments, but please advise me if this is not the case.

Thanks,

Kind regards,

Jane Cooper  
Environmental Health Officer  
Environmental Health  
Tel: +44 (0)1444 477437  
Email: [jane.cooper@midsussex.gov.uk](mailto:jane.cooper@midsussex.gov.uk)  
Website: [www.midsussex.gov.uk](http://www.midsussex.gov.uk)



"Working together for a better Mid Sussex"